

# 6491B / H07Z-R / BS EN 50525-3-41 Cable



Eland Product Group: **A3Z**

## APPLICATION

Suitable for use in conduit and for fixed, protected installation. In particular for installation where fire, smoke emission and toxic fumes create a potential threat.

## CONSTRUCTION

### Conductor

Class 2 stranded copper conductor according to BS EN 60228 (previously BS 6360)

### Insulation

LSZH (Low Smoke Zero Halogen) Type EI5 according to BS EN 50363

## CABLE STANDARDS

BS EN 50525-3-41 (previously BS 7211), BASEC approved



The electrical and dimensional properties of this product are measured by the Technical and Quality Assurance department at the Eland Cables laboratory. Cable performance in respect of conductor resistance, construction quality (workmanship), dimensional consistency, and other parameters are verified to published standards and approved product drawings. Conformance to RoHS (Restriction of the use of Hazardous Substances) is determined and confirmed.

## CHARACTERISTICS

### Voltage Rating (U<sub>o</sub>/U)

450/750V

### Temperature Rating

Fixed: 0°C to +90°C

### Minimum Bending Radius

Up to 10mm<sup>2</sup>: 4 x overall diameter

10mm<sup>2</sup> to 25mm<sup>2</sup>: 5 x overall diameter

Above 25mm<sup>2</sup>: 6 x overall diameter

### Insulation Colour

● Red ● Black ● Blue ● Yellow ● Orange ○ White

● Green/Yellow ● Grey ● Brown ● Violet ● Pink

## DIMENSIONS

ELAND PART NO.	NOMINAL CROSS SECTIONAL AREA mm <sup>2</sup>	NOMINAL THICKNESS OF INSULATION mm	NOMINAL OVERALL DIAMETER mm	NOMINAL WEIGHT kg/km
A3Z6491B015*	1.5	0.7	3.4	22
A3Z6491B025*	2.5	0.8	4.1	35
A3Z6491B040*	4	0.8	4.7	50
A3Z6491B060*	6	0.8	5.4	72
A3Z6491B10*	10	1	6.8	121
A3Z6491B16*	16	1	8	182
A3Z6491B25*	25	1.2	9.8	285
A3Z6491B35*	35	1.2	11	390
A3Z6491B50*	50	1.4	13.2	510
A3Z6491B70*	70	1.4	15.1	710
A3Z6491B95*	95	1.6	17	980
A3Z6491B120*	120	1.6	19	1220
A3Z6491B150*	150	1.8	21	1500
A3Z6491B185*	185	2	23.5	1910
A3Z6491B240*	240	2.2	26.5	2490
A3Z6491B300*	300	2.4	29.5	3100
A3Z6491B400*	400	2.6	33.5	3950
A3Z6491B500*	500	2.8	37	5000
A3Z6491B630*	630	2.8	41	6350

\*Eland Part No. shown above designate the sheath colour (\*). For each colour substitute \* for a colour code as listed below. e.g. A3Z6491B040BR = 4mm<sup>2</sup> Brown

## Colour Codes

COLOUR	Black	Blue	Grey	Green/ Yellow	Orange	Red	Pink	Yellow	Violet	Brown	White
CODE	BK	BL	GR	GY	OR	RD	PK	YW	VI	BR	WH

## CONDUCTORS

### Class 2 Stranded Conductors for Single Core and Multi-Core Cables

NOMINAL CROSS SECTIONAL AREA mm <sup>2</sup>	MINIMUM NO. OF WIRES IN CONDUCTOR						MAXIMUM RESISTANCE OF CONDUCTOR AT 20°C
	Circular		Circular Compacted		Shaped		Annealed Copper Conductor
	Cu	Al	Cu	Al	Cu	Al	Plain Wires ohms/km
1.5	7	-	6	-	-	-	12.1
2.5	7	-	6	-	-	-	7.41
4	7	-	6	-	-	-	4.61
6	7	-	6	-	-	-	3.08
10	7	7	6	6	-	-	1.83
16	7	7	6	6	-	-	1.15
25	7	7	6	6	6	6	0.727
35	7	7	6	6	6	6	0.524
50	19	19	6	6	6	6	0.387
70	19	19	12	12	12	12	0.268
95	19	19	15	15	15	15	0.193
120	37	37	18	15	18	15	0.153
150	37	37	18	15	18	15	0.124
185	37	37	30	30	30	30	0.0991
240	37	37	34	30	34	30	0.0754
300	61	61	34	30	34	30	0.0601
400	61	61	53	53	53	53	0.047
500	61	61	53	53	53	53	0.0366
630	91	91	53	53	53	53	0.0283

The above table is in accordance with BS EN 60228 (previously BS 6360)

## ELECTRICAL CHARACTERISTICS

### Current Carrying Capacity

NOMINAL CROSS SECTIONAL AREA mm <sup>2</sup>	REFERENCE METHOD A (ENCLOSED IN CONDUIT IN THERMALLY INSULATING WALL ETC)		REFERENCE METHOD B (ENCLOSED IN CONDUIT ON A WALL OR IN TRUNKING ETC)		REFERENCE METHOD C (CLIPPED DIRECT)		REFERENCE METHOD F (IN FREE AIR OR ON A PERFORATED CABLE TRAY ETC HORIZONTAL OR VERTICAL ETC) TOUCHING			REFERENCE METHOD G (IN FREE AIR) SPACED 1 x OD	
	2 Cables Single-Phase AC or DC Amps	3 or 4 Cables Three-Phase AC Amps	2 Cables Single-Phase AC or DC Amps	3 or 4 Cables Three-Phase AC Amps	2 Cables Single-Phase AC or DC Amps	3 or 4 Cables Three-Phase AC Amps	2 Cables Single-Phase AC or DC Amps	3 Cables Three-Phase AC		Horizontal	Vertical
								Flat Amps	Trefoil Amps		
1.5	19	17	23	20	25	23	-	-	-	-	-
2.5	26	23	31	28	34	31	-	-	-	-	-
4	35	31	42	37	46	41	-	-	-	-	-
6	45	40	54	48	59	54	-	-	-	-	-
10	61	54	75	66	81	74	-	-	-	-	-
16	81	73	100	88	109	99	-	-	-	-	-
25	106	95	133	117	143	130	161	141	135	182	161
35	131	117	164	144	176	161	200	176	169	226	201
50	158	141	198	175	228	209	242	216	207	275	246
70	200	179	253	222	293	268	310	279	268	353	318
95	241	216	306	269	355	326	377	342	328	430	389
120	278	249	354	312	413	379	437	400	383	500	454
150	318	285	393	342	476	436	504	464	444	577	527
185	362	324	449	384	545	500	575	533	510	661	605
240	424	380	528	450	644	590	679	634	607	781	719
300	486	435	603	514	743	681	783	736	703	902	833
400	-	-	683	584	868	793	940	868	823	1085	1008
500	-	-	783	666	990	904	1083	998	946	1253	1169
630	-	-	900	764	1130	1033	1254	1151	1088	1454	1362

Ambient temperature: 30°C  
Conductor operating temperature: 90°C

#### Notes

1. Where a conductor operates at a temperature exceeding 70°C it must be ascertained that the equipment connected to the conductor is suitable for the conductor operating temperature (see Regulations 512.1.2 of the 17th Edition of IEE Wiring Regulations)

2. Where cables in this table are connected to equipment or accessories designed to operate at a temperature not exceeding 70°C, the current ratings given in the equivalent table for 70°C thermoplastic insulated cables (Table 4D1A) MUST BE USED ( See Regulation 523.1 of the 17th Edition of IEE Wiring Regulations)

The above table is in accordance with Table 4E1A from the 17th Edition of IEE Wiring Regulations.

## Voltage Drop

NOMINAL CROSS SECTIONAL AREA mm <sup>2</sup>	2 CABLES DC mV/A/m	2 CABLES SINGLE-PHASE AC mV/A/m									3 OR 4 CABLES THREE-PHASE AC mV/A/m											
		Reference Methods A and B (enclosed in conduit or trunking)			Reference Methods C, F and G (clipped direct, on tray or in free air)						Reference Methods A and B (enclosed in conduit or trunking)			Reference Methods C, F and G (clipped direct, on tray or in free air)								
					Cables Touching			Cables Spaced*						Cables touching, Trefoil		Cables touching, Flat		Cables spaced*, Flat				
1.5	31	31			31			31			27			27		27		27				
2.5	19	19			19			19			16			16		16		16				
4	12	12			12			12			10			10		10		10				
6	7.9	7.9			7.9			7.9			6.8			6.8		6.8		6.8				
10	4.7	4.7			4.7			4.7			4			4		4		4				
16	2.9	2.9			2.9			2.9			2.5			2.5		2.5		2.5				
		r	x	z	r	x	z	r	x	z	r	x	z	r	x	z	r	x	z	r	x	z
25	1.85	1.85	0.31	1.90	1.85	0.19	1.85	1.85	0.28	1.85	1.60	0.27	1.65	1.60	0.165	1.60	1.60	0.19	1.60	1.60	0.27	1.65
35	1.35	1.35	0.29	1.35	1.35	0.18	1.35	1.35	0.27	1.35	1.15	0.25	1.15	1.15	0.155	1.15	1.15	0.18	1.15	1.15	0.26	1.20
50	0.99	1.00	0.29	1.05	0.99	0.18	1.00	0.99	0.27	1.00	0.87	0.25	0.90	0.86	0.155	0.87	0.86	0.18	0.87	0.86	0.26	0.89
70	0.68	0.70	0.28	0.75	0.68	0.175	0.71	0.68	0.26	0.73	0.60	0.24	0.65	0.59	0.15	0.61	0.59	0.175	0.62	0.59	0.25	0.65
95	0.49	0.51	0.27	0.58	0.49	0.17	0.52	0.49	0.26	0.56	0.44	0.23	0.50	0.43	0.145	0.45	0.43	0.17	0.46	0.43	0.25	0.49
120	0.39	0.41	0.26	0.48	0.39	0.165	0.43	0.39	0.25	0.47	0.35	0.23	0.42	0.34	0.14	0.37	0.34	0.165	0.38	0.34	0.24	0.42
150	0.32	0.33	0.26	0.43	0.32	0.165	0.36	0.32	0.25	0.41	0.29	0.23	0.37	0.28	0.14	0.31	0.28	0.165	0.32	0.28	0.24	0.37
185	0.25	0.27	0.26	0.37	0.26	0.165	0.30	0.25	0.25	0.36	0.23	0.23	0.32	0.22	0.14	0.26	0.22	0.165	0.28	0.22	0.24	0.33
240	0.19	0.21	0.26	0.33	0.20	0.16	0.25	0.195	0.25	0.31	0.185	0.22	0.29	0.17	0.14	0.22	0.17	0.165	0.24	0.17	0.24	0.29
300	0.155	0.175	0.25	0.31	0.16	0.16	0.22	0.155	0.25	0.29	0.15	0.22	0.27	0.14	0.14	0.195	0.135	0.16	0.21	0.135	0.24	0.27
400	0.12	0.14	0.25	0.29	0.13	0.155	0.20	0.125	0.24	0.27	0.125	0.22	0.25	0.11	0.135	0.175	0.11	0.16	0.195	0.11	0.24	0.26
500	0.093	0.12	0.25	0.28	0.105	0.155	0.185	0.098	0.24	0.26	0.10	0.22	0.24	0.09	0.135	0.16	0.088	0.16	0.18	0.085	0.24	0.25
630	0.072	0.10	0.25	0.27	0.086	0.155	0.175	0.078	0.24	0.25	0.088	0.21	0.23	0.074	0.135	0.15	0.071	0.16	0.17	0.068	0.23	0.24

Conductor Operating Temperature: 90°C

r = Resistive Component  
 x = Reactive Component  
 z = Impedance Value

\* Spacings larger than those specified in Method 12 (see table 4A of the 17th Edition of IEE Wiring Regulations) will result in larger volt drop.

The above table is in accordance with Table 4E1B from the 17th Edition of IEE Wiring Regulations.

## DE-RATING FACTORS

For Ambient Air Temperatures other than 30°C

AMBIENT TEMPERATURE	30°C	35°C	40°C	45°C	50°C	55°C	60°C	65°C	70°C
DE-RATING FACTOR	1.00	0.96	0.91	0.87	0.82	0.76	0.71	0.65	0.58

The above table is in accordance with Table 4B1 of the 17th Edition of IEE Wiring Regulations.